

MIST5 & MIST7 Misting Kits

Installation and Maintenance Instructions.

THESE INSTRUCTIONS MUST BE READ FULLY BEFORE COMMENCING INSTALLATION.

Owner / installer: The life of this unit will be increased if its use, installation and maintenance is carried out in accordance with these instructions. It is the responsibility of the installer to verify that the installation is in accordance with the following standards.

1. General

- 1.1 It is important these Installation and Maintenance Instructions are fully adhered to.
- 1.2 These instructions cover only the Hydor product
- 1.3 The Misting Kits are designed to fit onto the Pedestal Recirculating Fan and the Turbulator Fans.
- 1.4 Kits consist of either 5 or 7 nozzles and should be used with fans up to 630mm diameter for 5 nozzles and 750mm diameter for the 7 nozzles.
- 1.5 This product is not intended for use by young children or infirm persons unless they have been adequately supervised by a responsible person. Young children should be supervised to ensure that they do not play with the cover.

WARNING The fan must be isolated from the power supply when the Misting Kit is being installed.

2. Installation

- 2.1 Ensure that the fan is switched off and isolated from the supply.
- 2.2 Particular attention should be carried out if the fan system involves automatic controls.
- 2.3 The hose should be attached to the propeller-side of the fan guard approximately 25mm from the outer edge in a circular form, so the air flow exiting the fan is passing over the nozzles.
- 2.4 The misting kit is secured on to the guard using five or seven "Tie-raps".
- 2.5 Ensure the water flow is not obstructed by the "Tie-raps" being too tight crimping the hose.
- 2.6 The hose has a 19mm hose thread water connector and this should be connected to a suitable water supply connection.

Guarantee

Hydor or its agents will, within a period of one year from the date of dispatch from their works, at its option, replace any goods, which are proven to have defects as a result of defective materials or workmanship. The goods must be inspected by a Hydor official and if necessary returned, with a Returns Note Number, carriage paid, for further examination.

Hydor Ltd

Hydor

Unit 8, Parkers Close, Downton Business Centre,
Downton, Salisbury, Wiltshire, SP5 3RB, UK

Tel: +44 (0) 1725 511422

Fax: +44 (0) 1725 512637

Email: info@hydor.co.uk

Web: www.hydor.co.uk

idealair group

Unit 1, Building 1, Sydney Corporate Park,
85 O'Riordan Street, Alexandria NSW 2015

Tel: +61 (02) 8073 3310

Fax: +61 (02) 8073 3320

Email: info@idealairgroup.com.au

AMS

11 Ingrid Road, Montague Gardens,
7442 Cape Town, Western Cape

Tel: +27 (0) 21 552 1077

Fax: +27 (0) 21 552 2797

MIST5 & MIST7 Inst Issue 1: 18.11.15